

Fault Estimation And Tolerant Anti-disturbance Switching Control for Switched Systems with Its Application to Circuit Systems

Ying Zhao¹, Xiaohui Liu¹, Pengyuan Li¹, and dan ma²

¹Dalian Maritime University

²Northeastern University State Key Laboratory of Synthetical Automation for Process Industries

March 10, 2023

Abstract

This study proposes a fault estimation and tolerant anti-disturbance switching control (ADSC) approach for the switched systems subject to the system fault and multiple disturbances. The fault dose not required to have a model. The disturbances contain the modeled unmeasurable part and the unmodeled measurable part. First, a composite switching estimator is constructed to simultaneously estimate the unavailable system state, fault and modeled disturbance. Then, by means of the estimator, a switching controller is developed to tolerant the fault and complement the modeled disturbance. Further, under the dwell time relevant switching signals, criteria are established to ensure the fault estimation performance and robustness property for the switched systems. Finally, via implementing the presented fault estimation and tolerant ADSC scheme on a switched circuit system to regulate the charge and flux, the reasonability of the established result is verified.

RESEARCH ARTICLE

Fault Estimation And Tolerant Anti-disturbance Switching Control for Switched Systems with Its Application to Circuit Systems

Ying Zhao¹ | Xiaohui Liu¹ | Pengyuan Li¹ | Dan Ma^{2,3}

¹School of Marine Electrical Engineering,
Dalian Maritime University, Dalian, China

²State Key Laboratory of Synthetical
Automation for Process Industries,
Shenyang, China

³School of Information Science and
Engineering, Northeastern University,
Shenyang, China

Correspondence

Ying Zhao, School of Marine Electrical
Engineering, Dalian Maritime
University, Dalian, China. Email:
yingz@dlnu.edu.cn

Summary

This study proposes a fault estimation and tolerant anti-disturbance switching control (ADSC) approach for the switched systems subject to the system fault and multiple disturbances. The fault does not required to have a model. The disturbances contain the modeled unmeasurable part and the unmodeled measurable part. First, a composite switching estimator is constructed to simultaneously estimate the unavailable system state, fault and modeled disturbance. Then, by means of the estimator, a switching controller is developed to tolerant the fault and complement the modeled disturbance. Further, under the dwell time relevant switching signals, criteria are established to ensure the fault estimation performance and robustness property for the switched systems. Finally, via implementing the presented fault estimation and tolerant ADSC scheme on a switched circuit system to regulate the charge and flux, the reasonability of the established result is verified.

KEYWORDS:

switched system, fault estimation, fault tolerant, multiple disturbances

1 | INTRODUCTION

Switched systems are peculiar hybrid systems featured by multi-modes and switching. The switching behavior is described by switched system and a function specified as the switching index. Numerous practical dynamics have features of multi-modes and switching, such as power electronics^{1,2}, aero-engine systems (see³⁻⁵), circuit systems^{6,7} and so on. Lots of efforts have been cast into the investigation of switched systems with a growing number of results attained. To list a few, the dissipativeness⁸, event-triggered (see⁹⁻¹⁵), adaptiveness¹⁶ and so on.

In practice, while a control system work, it may suffer from various unexpected factors. Disturbances and failures are two typical unwelcome characteristics which usually cause a reduction on reliability and security of the practical processes.

On the one hand, to deal with the faults in the systems, many fault tolerant control (FTC) schemes have been established. During the process of fault tolerant, fault estimation occupies a vital position. Lots of contributions have been devoted to fault estimation. For the different occurrence parts of the system failure, different fault estimators have been developed for estimating the faults. The robust estimator^{17,18}, sliding mode estimator¹⁹, descriptor estimator²⁰, adaptive estimator^{21,22} are the well developed fault estimators. It is necessary to point out that a matching constraint assumption is adapted in the construction of many fault estimators see²³ for example. Luckily,²⁴ presented a relaxation on the matching constraint and then attained the fault tolerant of a liner system. However, the considered system is non-switched. For the existing investigations on the fault estimation and FTC issues of switched systems in²⁵, this matching constraint still exists. This constitutes one motivation of this paper.

On the other hand, multiple types of disturbances often simultaneously exist as soon as a control system operates in practice. Recently, several kinds of effective disturbance estimators have been developed, like the composite estimator²⁶, extended estimator²⁷ and equivalent input estimator^{28,29}, to achieve the elimination or suppression of the disturbances. Notice that the composite estimator is favorable due to its perfect compensation of the unmeasurable modeled disturbance. The composite estimator technique has been successfully employed to combine with other control techniques to pursue the corresponding system performance with a good disturbance suppression property. For switched systems, to mention a few, the composite estimator approach has been combined with the H_∞ control scheme³⁰, the bumpless transfer control strategy (see³¹⁻³⁴) and the adaptive control way (see³⁵⁻³⁷) to obtain the better robustness, bumpless transfer performance and the adaptive property, respectively. For the FTC issue of switched systems, the study of composite anti-disturbance control is quite few.^{38,39} addressed the FTC issue for the switched stochastic system with the mismatched unmodeled disturbance instead of the modeled disturbance and the fault occur at the actuator. Notice that the process fault is more general than the actuator fault. Therefore, it is more general and interesting to make an investigation on the FTC issue for the switched systems with the process fault and multiple disturbances.

Via this paper, the fault estimation based as fault tolerant ADSC problem of switched systems encountered by both process fault and multiple disturbances are studied. By designing the disturbance estimator, fault estimator without the matching constraint, the unknown disturbance and fault are estimated. Then, according to the observers, the fault tolerant anti-disturbance switching controller is established to pursue the practical stability of the switched systems under the dwell-time relevant switching index. Finally, the reasonability of the developed fault tolerant ADSC control scheme is verified by a switched circuit model. Different from the existing investigations, three features of this paper is worth noticed.

i) The matching limitation used in the fault estimation process of switched systems is taken away. This renders that a wider range of faults can be mastered.

ii) The multiple disturbances are suppressed or compensated while addressing the fault. The disturbances include the modeled disturbances and unmodeled disturbances. This coincides with practice better.

iii) The criterion is formed to ensure that the established fault tolerant ADSC scheme can force the switched systems to be stable.

Structure. Section 2 introduces the formulation of the fault estimation and tolerant ADSC issue. The fault tolerant ADSC technique is developed in Section 3. Section 4 verifies the effectiveness of the established fault estimator and tolerant ADSC strategy. The conclusions are obtained by Section 5.

Notation. $L_2[t_0, \infty)$ suggests the set of square integrable vector functions on $[t_0, \infty)$. $\text{diag}\{A, B\}$ represents a diagonal matrix with A and B specifying elements on the diagonal. $\text{sym}(A)$ denotes $A + A^T$.

2 | PROBLEM FORMULATION

We take the following switched system

$$\begin{aligned}\dot{x}(t) &= J_{\theta(t)}x(t) + L_{\theta(t)}[u(t) + \Psi_1(t)] + M_{\theta(t)}\Psi_2(t) + S_{\theta(t)}f(t), \\ y(t) &= N_{\theta(t)}x(t) + O_{\theta(t)}\Psi_2(t),\end{aligned}\tag{1}$$

into account, $x(t) \in R^n$, $u(t) \in R^w$ and $y(t) \in R^q$ are the system state, control input and control output, respectively, $\Psi_1(t) \in R^w$ and $\Psi_2(t) \in R^p$ are the disturbance input, $f(t) \in R^r$ indicates the fault signal, $\theta(t)$ represents switching logic (SL). For convenience, we exploit the sequence

$$\{x_0; (q_0, t_0), (q_1, t_1), \dots, (q_n, t_n), \dots | q_n \in \Xi, n \in N\}$$

to express the switching index $\theta(t)$, where x_0, t_0, t_n refer to the incipient state, incipient point and n th switching point, respectively, $\Xi = \{1, 2, \dots, m\}$ refers to the amount of the subsystems, and $\theta(t) = q_n$ specifies that the q_n th submodel activates.

In the system (1), the state $x(t)$, the disturbance $\Psi_1(t)$ and the fault $f(t)$ are pre-unknown, $\Psi_1(t)$ comes from the following model

$$\begin{aligned}\dot{\xi}(t) &= P_{\theta(t)}\xi(t) + Q_{\theta(t)}\Psi_3(t), \\ \Psi_1(t) &= R_{\theta(t)}\xi(t),\end{aligned}\tag{2}$$

in which $\xi(t) \in R^h$ refers to the state, $\Psi_3(t) \in R^r$ refers to the disturbance input satisfying the same property as $\Psi_2(t)$, namely, $\Psi_2(t)$ and $\Psi_3(t)$ all belong $L_2[0, \infty)$.

For the system (1), the following assumptions and definition are needed.

Assumption 1. S_i is the full rank matrix, namely, $\text{rank}(S_i) = r, i \in \Xi$.

Assumption 2. For any complex value χ having non-negative real part, it yields that

$$\text{rank} \begin{bmatrix} J_i - \chi I & S_i \\ N_i & 0 \end{bmatrix} = n + \text{rank}(S_i), i \in \Xi.$$

Assumption 3. $\text{Rank}(L_i, S_i) = \text{rank}(L_i), i \in \Xi$.

Assumption 4. The unknown time-varying fault $f(t)$ satisfies $\|\dot{f}(t)\| \leq \aleph$ with $\aleph \geq 0$ being a specified constant.

Definition 1. ⁴⁰For any SL $\theta(t)$ and time $t_b > t_a \geq 0$, if the quantity of switchings for the SL $\theta(t)$ during the interval $[t_a, t_b]$ ensures

$$\rho_\theta(t_a, t_b) \leq \frac{t_b - t_a}{s}$$

then, the invariable s is the average dwell time of the SL $\theta(t)$.

The control aim is to estimate the unknown state $x(t)$, fault $f(t)$ and disturbance $\Psi_1(t)$, and then design a control scheme to tolerant the fault $f(t)$, suppress the disturbance $\Psi_1(t), \Psi_2(t)$ and $\Psi_3(t)$.

First, in order to capture the disturbance $\Psi_1(t)$, we design the following observer

$$\begin{aligned} \dot{\eta}(t) &= (P_{\theta(t)} + \Lambda L_{\theta(t)} R_{\theta(t)})[\eta(t) - \Lambda x(t)] + \Lambda[J_{\theta(t)}x(t) + L_{\theta(t)}u(t) + S_{\theta(t)}f(t)], \\ \hat{\xi}(t) &= \eta(t) - \Lambda x(t), \\ \hat{\Psi}_1(t) &= R_{\theta(t)}\hat{\xi}(t), \end{aligned} \quad (3)$$

where $\hat{\Psi}_1(t)$ represents the estimation of the disturbance $\Psi_1(t)$, Λ is the observer gain to be yielded.

Then, for purpose of getting the state of $x(t)$ and the fault $f(t)$, we introduce the following variable

$$r(t) = f(t) - Wx(t), \quad (4)$$

and constructing the following observer

$$\begin{aligned} \dot{\hat{x}}(t) &= J_{\theta(t)}\hat{x} + L_{\theta(t)}[u(t) + \hat{\Psi}_1(t)] + M_{\theta(t)}\Psi_2(t) + S_{\theta(t)}\hat{f}(t) + T_{\theta(t)}[y(t) - \hat{y}(t)], \\ \dot{\hat{r}}(t) &= -W S_{\theta(t)}\hat{r}(t) - W\{J_{\theta(t)}\hat{x}(t) + L_{\theta(t)}[u(t) + \hat{\Psi}_1(t)] + M_{\theta(t)}\Psi_2(t) + S_{\theta(t)}W\hat{x}(t)\}, \\ \hat{y}(t) &= N_{\theta(t)}\hat{x}(t) + O_{\theta(t)}\Psi_2(t), \\ \hat{f}(t) &= \hat{r}(t) + W\hat{x}(t), \end{aligned} \quad (5)$$

among them, $\hat{x}(t)$, $\hat{r}(t)$, $\hat{y}(t)$, $\hat{f}(t)$ are the estimation of $x(t)$, $r(t)$, $y(t)$ and $f(t)$, respectively, W is a matrix to be specified satisfying $W = v_i S_i^T, i \in \Xi$, v is a scalar to be solved.

Further, definite the estimation errors

$$\begin{aligned} e_x(t) &= x(t) - \hat{x}(t), e_r(t) = r(t) - \hat{r}(t), \\ e_f(t) &= f(t) - \hat{f}(t), e_\xi(t) = \xi(t) - \hat{\xi}(t), \end{aligned}$$

thus, the error dynamics are attained as

$$\begin{aligned} \dot{e}_x(t) &= \dot{x}(t) - \dot{\hat{x}}(t) \\ &= J_{\theta(t)}x(t) + L_{\theta(t)}[u(t) + \Psi_1(t)] + M_{\theta(t)}\Psi_2(t) + S_{\theta(t)}f(t) - \{J_{\theta(t)}\hat{x}(t) + L_{\theta(t)}[u(t) + \hat{\Psi}_1(t)] \\ &\quad + M_{\theta(t)}\Psi_2(t) + S_{\theta(t)}\hat{f}(t) + T_{\theta(t)}[y(t) - \hat{y}(t)]\} \\ &= (J_{\theta(t)} - T_{\theta(t)}N_{\theta(t)})e_x(t) + S_{\theta(t)}e_f(t) + L_{\theta(t)}R_{\theta(t)}e_\xi(t) \\ &= (J_{\theta(t)} - T_{\theta(t)}N_{\theta(t)} + S_{\theta(t)}W)e_x(t) + S_{\theta(t)}e_r(t) + L_{\theta(t)}R_{\theta(t)}e_\xi(t), \end{aligned} \quad (6)$$

$$\begin{aligned}
\dot{e}_\xi(t) &= \dot{\xi}(t) - \dot{\hat{\xi}}(t) \\
&= P_{\theta(t)}\xi(t) + Q_{\theta(t)}\Psi_3(t) - [\dot{\eta}(t) - \Lambda\dot{x}(t)] \\
&= P_{\theta(t)}\xi(t) + Q_{\theta(t)}\Psi_3(t) - \{(P_{\theta(t)} + \Lambda L_{\theta(t)}R_{\theta(t)})[\eta(t) - \Lambda x(t)] + \Lambda[J_{\theta(t)}x(t) + L_{\theta(t)}u(t) + S_{\theta(t)}\mathbb{f}(t)]\} \\
&= (P_{\theta(t)} + \Lambda L_{\theta(t)}R_{\theta(t)})e_\xi(t) + Q_{\theta(t)}\Psi_3(t) + \Lambda M_{\theta(t)}\Psi_2(t), \\
\dot{e}_r(t) &= \dot{r}(t) - \dot{\hat{r}}(t) \\
&= \dot{\mathbb{f}}(t) - W\{J_{\theta(t)}x(t) + L_{\theta(t)}[u(t) + \Psi_1(t)] + M_{\theta(t)}\Psi_2(t) + S_{\theta(t)}\mathbb{f}(t)\} + WS_{\theta(t)}\hat{r}(t) \\
&\quad + W\{J_{\theta(t)}\hat{x}(t) + L_{\theta(t)}[u(t) + \hat{\Psi}_1(t)] + M_{\theta(t)}\Psi_2(t) + S_{\theta(t)}W\hat{x}(t)\} \\
&= \dot{\mathbb{f}}(t) - (WJ_{\theta(t)} + WS_{\theta(t)}W)e_x(t) - WL_{\theta(t)}R_{\theta(t)}e_\xi(t) - WS_{\theta(t)}e_r(t).
\end{aligned}$$

Next, according to Assumption 3 and the estimators (3), (5), we can design the following controller

$$u(t) = -\hat{\Psi}_1(t) + Y_{\theta(t)}\hat{x}(t) - L_{\theta(t)}^*S_{\theta(t)}\hat{\mathbb{f}}(t), \quad (7)$$

where $Y_i, i \in \Xi$ are the controller gain need to be selected.

By substituting the control input (7) into (5), the dynamics of the whole closed-loop system can be obtained within

$$\begin{aligned}
\dot{\hat{x}}(t) &= J_{\theta(t)}\hat{x}(t) + L_{\theta(t)}[-\hat{\Psi}_1(t) + Y_{\theta(t)}\hat{x}(t) - L_{\theta(t)}^*S_{\theta(t)}\hat{\mathbb{f}}(t) \\
&\quad + \hat{\Psi}_1(t)] + M_{\theta(t)}\Psi_2(t) + S_{\theta(t)}\hat{\mathbb{f}}(t) + T_{\theta(t)}[y(t) - \hat{y}(t)] \\
&= (J_{\theta(t)} + L_{\theta(t)}Y_{\theta(t)})\hat{x}(t) + M_{\theta(t)}\Psi_2(t) + T_{\theta(t)}N_{\theta(t)}e_x(t).
\end{aligned} \quad (8)$$

Combining (2) and (8), we attain the augmented system

$$\begin{aligned}
\dot{\alpha}(t) &= \Sigma_{1\theta(t)}\alpha(t) + \Sigma_{2\theta(t)}\Psi(t) + \Sigma_{3\theta(t)}\hat{\mathbb{f}}(t), \\
y(t) &= \Gamma_{1\theta}\alpha(t) + \Gamma_{2\theta}\Psi(t),
\end{aligned} \quad (9)$$

where

$$\begin{aligned}
\alpha(t) &= [\hat{x}^T(t) \ e_x^T(t) \ e_r^T(t) \ e_\xi^T(t)]^T \Sigma_{2i} = \begin{bmatrix} M_i & 0 \\ 0 & 0 \\ 0 & 0 \\ \Lambda M_i & Q_i \end{bmatrix}, \Sigma_{3i} = \begin{bmatrix} 0 \\ 0 \\ I \\ 0 \end{bmatrix}, \\
\Sigma_{1i} &= \begin{bmatrix} J_i + L_i Y_i & T_i N_i & 0 & 0 \\ 0 & J_i - T_i N_i + S_i W & S_i & L_i R_i \\ 0 & -W J_i - W S_i W & -W S_i & -W L_i R_i \\ 0 & 0 & 0 & P_i + \Lambda L_i R_i \end{bmatrix}, \Gamma_{1i} = [N_i \ N_i \ 0 \ 0], \Gamma_{2\theta} = [O_i \ 0]
\end{aligned}$$

Based on the augmented system (9), the control aim is reformulated as

- i) If the disturbance $\Psi(t)$ and $\mathbb{f}(t)$ are absent, then the system (9) is asymptotical stable.
- ii) If the disturbance $\Psi(t)$ is absent, the system (9) is practical stable.
- iii) If the disturbance $\Psi(t)$ and the fault $\mathbb{f}(t)$ all exist, then the following L_2 gain property is ensured:

$$\int_0^\infty e^{-\delta_0 t} y^T(t) y(t) dt \leq \beta \int_0^\infty \Psi^T(t) \Psi(t) dt \quad (10)$$

where β is the L_2 -gain level, δ_0 and β are given positive constant.

If the above control aim is reached, then the fault estimation and tolerant ADSC issue of the system (1) is solvable. The structure of the fault estimation and tolerant ADSC scheme is depicted by Fig. 1.

3 | MAIN RESULT

In this part, the fault estimation and tolerant ADSC scheme is designed for the system (1) to force the fault tolerant and multiple disturbances alleviation.




Figure 1 The structure of the fault estimation and tolerant anti-disturbance switching control scheme.

Theorem 1. Consider the system (9) with the given scalars $\delta_0 > 0$, $\beta > 0$, $\mu \geq 1$. Assume that the positive definite matrices H_i , matrices Y_i , T_i , Λ can be founded to ensure

$$\begin{bmatrix} \Sigma_{1i}^T H_i + H_i \Sigma_{1i} + \Gamma_{1i}^T \Gamma_{1i} + c H_i & H_i \Sigma_{2i} + \Gamma_{1i}^T \Gamma_{2i} \\ * & \Gamma_{2i}^T \Gamma_{2i} - \beta I \end{bmatrix} < 0, \quad (11)$$

$$H_i < \mu H_j, i, j \in \Xi, \quad (12)$$

then under the estimators (3), (5) and the dwell-time relevant SL $\theta(t)$ ensuring

$$s_d > s_d^* = \frac{\ln \mu}{\delta}, \delta \in (0, \delta_0), \quad (13)$$

the fault estimation and tolerant ADSC issue can be solved by the controller (7).

For $\theta(t) = i$, take

$$V_i(t) = \alpha^T(t) H_i \alpha(t), \quad (14)$$

as the Lyapunov function of the i th subsystem for the system (9).

Thus, it generates that

$$\begin{aligned} \dot{V}_i(t) &= \dot{\alpha}^T(t) H_i \alpha(t) + \alpha^T(t) H_i \dot{\alpha}(t) \\ &= 2\alpha^T(t) H_i \Sigma_{1i} \alpha(t) + 2\alpha^T(t) H_i \Sigma_{2i} \Psi(t). \end{aligned} \quad (15)$$

Futher, it yields that

$$\begin{aligned}
 & \dot{V}_i(t) + y^T(t)y(t) - \beta \Psi^T(t)\Psi(t) + cV_i(t) \\
 &= \begin{bmatrix} \alpha(t) \\ \Psi(t) \end{bmatrix}^T \begin{bmatrix} \iota_{11} & H_i \Sigma_{2i} + \Gamma_{1i}^T \Gamma_{2i} \\ * & \Gamma_{2i}^T \Gamma_{2i} - \beta I \end{bmatrix} \begin{bmatrix} \alpha(t) \\ \Psi(t) \end{bmatrix} + cV_i(t), \\
 &= \begin{bmatrix} \alpha(t) \\ \Psi(t) \end{bmatrix}^T \begin{bmatrix} \iota_{11} + cH_i & H_i \Sigma_{2i} + \Gamma_{1i}^T \Gamma_{2i} \\ * & \Gamma_{2i}^T \Gamma_{2i} - \beta I \end{bmatrix} \begin{bmatrix} \alpha(t) \\ \Psi(t) \end{bmatrix}
 \end{aligned} \tag{16}$$

where

$$\iota_{11} = \Sigma_{1i}^T H_i + H_i \Sigma_{1i} + \Gamma_{1i}^T \Gamma_{1i}.$$

From (11), we have

$$\dot{V}_i(t) + y^T(t)y(t) - \beta^2 \Psi^T(t)\Psi(t) + cV_i(t) \leq 0. \tag{17}$$

When $\Psi(t) = 0$ from (11), it is not hard to render that

$$\dot{V}_i(\alpha(t)) \leq -\delta_0 V_i(\alpha(t)). \tag{18}$$

According to (12), we deduce

$$V_i(\alpha(t)) \leq \mu V_j(\alpha(t)), \forall i, j \in \Xi. \tag{19}$$

Combing (18) and (19), we are clear that

$$\dot{V}_i(\alpha(t)) \leq \mu^{\rho_\theta(0,t)} e^{-\delta_0 t} V(0) = e^{\rho_\theta(0,t) \ln \mu - \delta_0 t} V(0), \tag{20}$$

where $V(t_k)$ represents the value of the Lyapunov function at the switching point t_k , $k = 0, 1, \dots, \rho_\theta(0, t)$. Further, due to $\rho_\theta(0, t) \leq s/s_d^*$ holds for any $s > 0$. It follows from (13) that

$$\rho_\theta(0, s) \ln \mu \leq \delta s. \tag{21}$$

Thus, we have

$$V_i(\epsilon(t)) \leq e^{-(\delta_0 - \delta)t} V(0). \tag{22}$$

This renders that the augmented system (9) is globally asymptotically stable when $\Psi(t) = 0$.

When $\Psi(t) \neq 0$, from (17) and (18), we deduce that

$$\begin{aligned}
 & V_i(\alpha(t)) \\
 & \leq V_i(\alpha(t_{\rho_\theta(0,t)})) e^{-\delta_0(t-t_{\rho_\theta(0,t)})} + \int_{t_{\rho_\theta(0,t)}}^t e^{-\delta_0(t-s)} \Upsilon(s) ds \\
 & \leq \mu V_i(\alpha(t_{\rho_\theta(0,t)}^-)) e^{-\delta_0(t-t_{\rho_\theta(0,t)})} + \int_{t_{\rho_\theta(0,t)}}^t e^{-\delta_0(t-s)} \Upsilon(s) ds \\
 & \leq \mu [V_i(\alpha(t_{\rho_\theta(0,t)-1})) e^{-\delta_0(t_{\rho_\theta(0,t)}-t_{\rho_\theta(0,t)-1})} + \int_{t_{\rho_\theta(0,t)-1}}^{t_{\rho_\theta(0,t)}} e^{-\delta_0(t_{\rho_\theta(0,t)}-s)} \Upsilon(s) ds] e^{-\delta_0(t-t_{\rho_\theta(0,t)})} + \int_{t_{\rho_\theta(0,t)}}^t e^{-\delta_0(t-s)} \Upsilon(s) ds \\
 & \leq \dots \dots \\
 & \leq \mu^{\rho_\theta(0,t)} e^{-\delta_0(t-t_0)} V_i(\alpha(t_0)) + \mu^{\rho_\theta(0,t)} \int_{t_0}^{t_1} e^{-\delta_0(t-s)} \Upsilon(s) ds + \mu^{\rho_\theta(0,t)-1} \int_{t_1}^{t_2} e^{-\delta_0(t-s)} \Upsilon(s) ds + \dots + \mu^0 \int_{t_{\rho_\theta(0,t)}}^t e^{-\delta_0(t-s)} \Upsilon(s) ds \\
 & = \mu^{\rho_\theta(t_0,t)} e^{-\delta_0(t-t_0)} V_i(\alpha(t_0)) + \int_{t_0}^t \mu^{\rho_\theta(s,t)} e^{-\delta_0(t-s)} \Upsilon(s) ds \\
 & = e^{-\delta_0(t-t_0)+\rho_\theta(t_0,t) \ln \mu} V_i(\alpha(t_0)) + \int_{t_0}^t e^{-\delta_0(t-s)+s(s,t) \ln \mu} \Upsilon(s) ds,
 \end{aligned} \tag{23}$$

where

$$\Upsilon(t) = -y^T(t)y(t) + \beta^2 \Psi^T(t)\Psi(t).$$

According to (23), letting $t_0 = 0$, under zero initial condition, we derive

$$\int_0^t e^{-\delta_0(t-s)+s(s,t) \ln \mu} \Upsilon(s) ds \leq 0. \quad (24)$$

Then, multiplying both sides of (24) by $e^{-\rho_\theta(0,t) \ln \mu}$, we can get

$$\int_0^t e^{-\delta_0(t-s)-\rho_\theta(0,s) \ln \mu} y^T(s)y(s) ds \leq \int_0^t e^{-\delta_0(t-s)-\rho_\theta(0,s) \ln \mu} \gamma^2 \Psi^T(s)\Psi(s) ds. \quad (25)$$

From (21), we derive

$$\int_0^t e^{-\delta_0(t-s)-\delta_0 s} y^T(s)y(s) ds \leq \int_0^t e^{-\delta_0(t-s)} \gamma^2 \Psi^T(s)\Psi(s) ds. \quad (26)$$

Integrating from $t : 0 \rightarrow \infty$ on two sides of the above inequality, we can deduce

$$\int_0^\infty e^{-\delta_0 s} y^T(s)y(s) ds \leq \gamma^2 \int_0^\infty \Psi^T(s)\Psi(s) ds.$$

Based on Definition 2, we know that the L_2 -gain property (10) holds.

Remark 1. Theorem 1 forms a criterion via which the fault estimation and tolerant ADSC issue of the system (1) is addressed in the case that the maintain condition is not required. Different from the fault estimation issue studied in²⁸, here, the multiple disturbances are considered which is more coincide with practice.

Next, we offer the design process of the controller (7) to solve the fault estimation and tolerant ADSC issue for the system (1).

Theorem 2. Consider the system (9). Suppose that for the given scalar $\mu > 1$, if there exist the positive define matrixes Z_{1i} , Z_{3i} and matrix Λ such that the relations

$$\begin{bmatrix} \sigma_{11i} & \partial_{12i} & 0 & 0 & \partial_{15i} & 0 & Z_{1i}N_i^T \\ * & \partial_{22i} & \partial_{23i} & L_i R_i & N_i^T O & 0 & 0 \\ * & * & \partial_{33i} & \partial_{34i} & 0 & 0 & 0 \\ * & * & * & \partial_{44i} & \Lambda M_i & Q_i & 0 \\ * & * & * & * & O_i^T O_i - \beta I & 0 & 0 \\ * & * & * & * & * & -\beta I & 0 \\ * & * & * & * & * & * & -I \end{bmatrix} < 0, \quad (27)$$

$$Z_{1i} < \mu Z_{1j}, i, j \in \Xi, \quad (28)$$

$$Z_{3i} < \mu Z_{3j}, i, j \in \Xi \quad (29)$$

hold, where

$$\begin{aligned} \sigma_{11i} &= \Omega_i L_i^T + Z_{1i} J_i^T + J_i Z_{1i} + L_i \Omega_i^T + c Z_{1i}, \\ \partial_{12i} &= T_i N_i + Z_{1i} N_i^T N_i, \\ \partial_{15i} &= Z_{1i} N_i^T O_i + M_i, \\ \partial_{22i} &= J_i^T - N_i^T T_i^T + v S_i S_i^T + J_i - T_i N_i + v S_i S_i^T + N_i^T N_i + c I, \\ \partial_{23i} &= -v J_i^T S_i - v^2 S_i S_i^T S_i + S_i Z_{3i}, \\ \partial_{33i} &= -v Z_{3i} S_i^T S_i - v S_i^T S_i Z_{3i} + c Z_{3i}, \\ \partial_{34i} &= -v S_i^T L_i R_i, \\ \partial_{44i} &= P_i^T + P_i + R_i^T L_i^T \Lambda^T + \Lambda L_i R_i + c I, \end{aligned}$$

then, the controller (7) is a solution to the fault tolerant ADSC issue for the system (9). Furthermore, the controller gain can be solved by $Y_i = \Omega_i^T Z_{1i}^{-1}$, $i \in \Xi$.

According to Theorem 1, if the constraints (11) and (12) are ensured, then the fault tolerant ADSC scheme for the system (9) is solved by the controller (7).

We firstly show that the condition (27) holds if and only if (11) holds. Let $H_i^{-1} = \text{diag}\{Z_{1i}, I, Z_{3i}, I\}$ and multiply $\text{diag}\{H_i^{-1}, I\}$ on both sides of (11), we can generate

$$\begin{bmatrix} \mathcal{P}_{11} & \Sigma_{2i} + H_i^{-1} \Gamma_{1i}^T \Gamma_{2i} \\ \Sigma_{2i}^T + \Gamma_{2i}^T \Gamma_{1i} H_i^{-1} & \Gamma_{2i}^T \Gamma_{2i} - \beta I \end{bmatrix} < 0, \quad (30)$$

where

$$\mathcal{P}_{11} = H_i^{-1} \Sigma_{1i}^T + \Sigma_{1i} H_i^{-1} + H_i^{-1} \Gamma_{1i}^T \Gamma_{1i} H_i^{-1} + \varepsilon \Sigma_{3i} \Sigma_{3i}^T + C H_i^{-1}.$$

Replacing $\Sigma_{1i}, \Sigma_{2i}, \Gamma_{1i}, \Gamma_{2i}$ in (30) by their specified expressions generates

$$\begin{bmatrix} \partial_{11i} & \partial_{12i} & 0 & 0 & \partial_{15i} & 0 \\ * & \partial_{22i} & \partial_{23i} & L_i R_i & N_i^T O_i & 0 \\ * & * & \partial_{33i} & \partial_{34i} & 0 & 0 \\ * & * & * & \partial_{44i} & \Lambda M_i & Q_i \\ * & * & * & * & O_i^T O_i - \beta I & 0 \\ * & * & * & * & * & -\beta I \end{bmatrix} < 0, \quad (31)$$

where

$$\partial_{11i} = Z_{1i} Y_i^T L_i^T + Z_{1i} J_i^T + J_i Z_{1i} + L_i Y_i Z_{1i} + Z_{1i} N_i^T N_i Z_{1i} + c Z_{1i},$$

Letting $Z_{1i} Y_i^T = \Omega_i$ and applying Schur complement lemma to (31), we get (27). This implies that the constraint (27) can ensure (11). On the other hand, multiplying $\text{diag}\{H_i^{-1}, I\}$ on two sides of (12) generates (4) and (29). Thus, it can be concluded that the controller (7) can cope with the fault tolerant ADSC problem of the system (9).

Remark 2. Via Theorem 2, the linear matrix inequality restraints are formed to serving for the computation of the fault estimation and tolerant anti-disturbance switching controller (7).

4 | VERIFICATION

This section illustrates the effectiveness of proposed fault estimation and tolerant ADSC method. Take the switched RLC circuit of³⁹ for example. The switched RLC circuit model is described by Fig. 2 and formulated by

$$\dot{x}(t) = J_{\theta(t)} x(t) + L_{\theta(t)} [u(t) + \Psi_1(t)] + M_{\theta(t)} \Psi_2(t) + S_{\theta(t)} f(t), \quad (32)$$

where $x^T(t) = [q^T(t) \ \phi_L^T(t)]$ with $q(t)$ denoting the charge across the capacitor $C_i, i = 1, 2$ and $\phi_L(t)$ denoting the flux across the inductance L ,

$$J_i = \begin{bmatrix} 0 & \frac{1}{L} \\ -\frac{1}{C_i} & -\frac{R}{L} \end{bmatrix},$$

C_i, R , and L are the capacitance, resistance and inductance, respectively, $\Psi_i(t), i = 1, 2$ are the disturbance input, $\Psi_1(t)$ is generated by the model (2), $\Psi_2(t) = \sin(t \times \exp(-2.3t))$, $f(t) = 4 \times \sin(t \times \exp(-2.3t))$ is the fault input.

Set $R = 5, L = 2, C_1 = 3, C_2 = 4$, the parameters of the model (32) are listed as follows:

$$L_1 = \begin{bmatrix} -0.8 \\ -0.6 \end{bmatrix}, L_2 = \begin{bmatrix} -0.6 \\ -0.8 \end{bmatrix}, M_1 = \begin{bmatrix} 0.5 & -0.5 \\ -0.3 & 0.1 \end{bmatrix}, M_2 = \begin{bmatrix} 0.2 & -0.6 \\ 0.1 & -0.2 \end{bmatrix},$$

$$S_1 = \begin{bmatrix} 0 & 0.9 \\ 0.3 & 0.1 \end{bmatrix}, S_2 = \begin{bmatrix} 0 & 1.8 \\ 0.6 & 0.2 \end{bmatrix}, N_1 = \begin{bmatrix} -0.1 & 0 \end{bmatrix}, N_2 = \begin{bmatrix} -0.8 & 0 \end{bmatrix},$$

$$O_1 = \begin{bmatrix} 0.1 & -0.5 \end{bmatrix}, O_2 = \begin{bmatrix} 0 & 0.6 \end{bmatrix}, P_1 = \begin{bmatrix} -0.2 & -0.1 \\ -0.1 & 0.2 \end{bmatrix}, P_2 = \begin{bmatrix} -0.2 & 0.1 \\ 0.1 & 0.1 \end{bmatrix},$$

$$Q_1 = \begin{bmatrix} -0.1 \\ 0.2 \end{bmatrix}, Q_2 = \begin{bmatrix} -0.2 \\ -0.6 \end{bmatrix}, R_1 = \begin{bmatrix} -0.1 & 1 \end{bmatrix}, R_2 = \begin{bmatrix} -0.6 & 6.6 \end{bmatrix}.$$




Figure 2 Switched circuit.

The task is to regulate the charge and flux of the switched RLC circuit model (32) with the disturbance $\Psi_1(t)$ and fault $f(t)$ estimated.

Let $\mu = 1.001$. By solving the constraints of Theorem 2, we derive

$$v_1 = 4, v_2 = 2,$$

$$\Omega_1 = 10^7 \times \begin{bmatrix} 2.9472 \\ -6.6961 \end{bmatrix}, \Omega_2 = 10^8 \times \begin{bmatrix} 1.2032 \\ -2.3383 \end{bmatrix},$$

$$Z_{11} = \begin{bmatrix} 7.3178 \times 10^3 & 739.2282 \\ 739.2282 & 7.7021 \times 10^7 \end{bmatrix}, Z_{12} = \begin{bmatrix} 7.3133 \times 10^3 & 738.8242 \\ 738.8242 & 7.6977 \times 10^7 \end{bmatrix},$$

$$Z_{31} = \begin{bmatrix} 6.7583 & -11.4838 \\ -11.4838 & 480.5620 \end{bmatrix}, Z_{32} = \begin{bmatrix} 6.7583 & -11.4838 \\ -11.4838 & 480.5624 \end{bmatrix},$$

$$\Lambda = \begin{bmatrix} 0.1557 & -3.5088 \\ -4.5851 & 44.1965 \end{bmatrix},$$

$$Y_1 = [4.0275 \times 10^3 \quad -0.9080], Y_2 = [4.0300 \times 10^3 \quad -0.9086],$$

$$T_1 = \begin{bmatrix} -1.4019 \times 10^8 \\ -26.4413 \end{bmatrix}, T_2 = \begin{bmatrix} -1.6429 \times 10^7 \\ 129.1762 \end{bmatrix}.$$

The simulation results are displayed by Figs. 3-7. Fig. 3 shows the SL $\theta(t)$. The state estimation of the switched RLC circuit model (32) is given in Fig. 4, which indicates that the unmeasurable state has been estimated by observed. The estimation errors of the state $x(t)$, disturbance $\Psi_1(t)$ and fault $f(t)$ are depicted by Figs. 5-7. From Figs. 5-7, we can see that all the estimation errors (4) are bounded. Therefore, we can claim that the fault estimation and tolerant ADSC scheme is effective in estimating the charge and flux of the switched RLC circuit model (32).

5 | CONCLUSIONS

In this investigation, a fault estimation and tolerant ADSC strategy has been developed for the switched systems subject to unmeasurable system state, disturbance and fault. First, the unmeasurable state, fault and disturbance have been estimated by co-design of a switching observer. In the observer, by virtue of an auxiliary variable, the traditional observer matching relation




Figure 3 Switching signal.




Figure 4 Estimation of state.




Figure 5 Estimation error of state.




Figure 6 Estimation error of disturbance.




Figure 7 Estimation error of fault.

in the fault estimation issue of switched systems has been relaxed. Third, under the developed estimator and controller, the condition has been formed to capture the solvability of the fault estimation and tolerant ADSC issue for the switched systems. In the end, by regulating the charge and flux of a switched circuit system, the effectiveness of the established fault estimation and tolerant ADSC method has been explained.

ACKNOWLEDGMENTS

This work was in part supported by the National Natural Science Foundation of China under Grant 62003070, and Natural Science Foundation of Liaoning Province under 2021-BS-077.

CONFLICT OF INTEREST

The authors declare no potential conflict of interests.

References

1. Rodriguesa L, Boyd S. Piecewise-affine state feedback for piecewise-affine slab systems using convex optimization. *Syst. Control Lett.* 2008;54(9):835-853.
2. Zhao Y, Yu S, Lian J. Anti-disturbance bumpless transfer control for switched systems with its application to switched circuit model. *IEEE Trans. Circuits Syst. II, Exp. Briefs.* 2020;67(12):3177-3181.
3. Yang D, Zhao J. Composite anti-disturbance control for switched systems via mixed state-dependent and time-driven switching. *IET Control Theory Appl.* 2016;10(16):1981-1990.
4. Li P, Zhao X, Qin H, Wang Z, Niu B. Dynamic event-triggered finite-time H_∞ tracking control of switched LPV aero-engine models. *IEEE Trans. Circuits Syst. II, Exp. Briefs.* 2022;69(3):1114-1118.
5. Shi Y, Sun X. Bumpless transfer control for switched linear systems and its application to aero-engines *IEEE Trans. Circuits Syst. I, Reg. Papers.* 2021;68(5):2171-2182.
6. Yang H, Cocquempot V, Jiang B. Fault tolerance analysis for switched systems via global passivity. *IEEE Trans. Circuits and Syst. II: Express Briefs.* 2008;55(12):1279-1283.
7. Sun T, Wang R, Zhang L, Zhao X. A fastly and slowly cyclic switching strategy for discrete-time cyclic switched systems and its application to inverter circuits. *IEEE Trans. Circuits Syst. II, Exp. Briefs.* 2022;69(3):1173-1177.

8. Rathinasamy S, Saminathan M, Palanisamy S, Karimi H, Anthoni S. EID estimator-based modified repetitive control for singular systems with time-varying delay. *Nonlinear Dynam.* 2017;89(2):1141-1156.
9. Li C, Xu Z. Stabilization of switched linear systems using an improved event-triggered control scheme. *Nonlinear Anal. Hybrid Syst.* 2021;41:1141-1156.
10. Liu L, Cui Y, Liu Y, Tong S. Adaptive event-triggered output feedback control for nonlinear switched systems based on full state constraints. *IEEE Trans. Circuits Syst. II, Exp. Briefs.* 2022;69(9):3779-3783.
11. Zhang J, Raissi T. Indefinite lyapunov-razumikhin functions-based stability and event-triggered control of switched nonlinear time-delay systems. *IEEE Trans. Circuits Syst. II, Exp. Briefs.* 2021;68(10):3286-3290.
12. Ruan X, Feng J, Xu C, Wang J, Zhao Y. Dynamic event-triggered pinning synchronization for switched impulsive complex networks with asynchronous switching. *IEEE Trans. Circuits Syst. II, Exp. Briefs.* 2022;69(4):2211-2215.
13. Qi W, Zong G, X. Zheng W. Adaptive event-triggered SMC for stochastic switching systems with semi-markov process and application to boost converter circuit model. *IEEE Trans. Circuits Syst. I, Reg. Papers.* 2021;68(2):786-796.
14. Zhang J, Li S, Xiang Z. Adaptive fuzzy output feedback event-triggered control for a class of switched nonlinear systems with sensor failures. *IEEE Trans. Circuits Syst. I, Reg. Papers.* 2020;67(12):5336-5346.
15. Qu H, Zhao J. Event-triggered H_∞ filtering for discrete-time switched systems under denial-of-service. *IEEE Trans. Circuits Syst. I, Reg. Papers.* 2021;68(6):2604-2615.
16. Yang C, Jiang Y, He W, Na J, Li Z, Xu B. Adaptive parameter estimation and control design for robot manipulators with finite-time convergence. *IEEE Trans. Ind. Electron.* 2018;65(10):8112-8123.
17. Gao Z, Ding S. Actuator fault robust estimation and faulttolerant control for a class of nonlinear descriptor systems. *Automatica.* 2007;43(5):912-920.
18. Guo Y, Jiang B, Zhang Y. A novel robust attitude control for quadrotor aircraft subject to actuator faults and wind gusts. *IEEE/CAA J Autom Sin* 2018;5(1):292-300.
19. Lee D, Park Y, Park Y. Robust H_1 sliding mode descriptor observer for fault and output disturbance estimation of uncertain systems. *IEEE Trans. Automat. Contr.* 2012;57(11):2928-2934.
20. Chadli M, Abdo A, X. Ding S. $H - H_\infty$ fault detection filter design for discrete-time Takagi-Sugeno fuzzy system. *Automatica.* 2013;49(7):1996-2005.
21. Jiang B, Staroswiecki M, Cocquempot V. Fault accommodation for nonlinear dynamic systems. *IEEE Trans. Automat. Contr.* 2006;51(9):1578-1583.
22. Sun S, Ren T, Wei X, Composite DOBC with fuzzy faulttolerant control for stochastic systems with unknown nonlinear dynamics. *Internat J Robust Nonlinear Control.* 2019;29(18):6605-6615.
23. Yong Z, Fang H, Zheng Y, Li X. Torus-event-based fault diagnosis for stochastic multirate time-varying systems with constrained fault. *IEEE Trans. Cybern.* 2020;50(6):2803-2813.
24. Zhu J, Yang G, Wang H, Wang F. Fault estimation for a class of nonlinear systems based on intermediate estimator. *IEEE Trans. Automat. Contr.* 2016;61(9):2518-2524.
25. Wang Y, Xu N, Liu Y, Zhao X. Adaptive fault-tolerant control for switched nonlinear systems based on command filter technique. *Appl. Math. Comput.* 2021;392. doi: 10.1016/j.amc.2020.125725.
26. Daafouz J, Geromel J, Deaecto G. A simple approach for switched control design with control bumps limitation. *Syst. Control Lett.* 2012;61(12):1215-1220.
27. Zhao Y, Zhao J, Fu J. Bumpless transfer control for switched fuzzy systems with L_2 -gain property. *IEEE Trans. Fuzzy Syst.* 2019;27(10):2039-2051.

28. Li J, Zhao J. Incremental passivity and incremental passivity-based rgulation for switched discrete-time systems. *IEEE Trans. Cybern.*. 2016;47(5):1122-1132.
29. Zhou L, She J, Zhang X, Zhang Z. Improving disturbance-rejection performance in a modified repetitive-control systembased on equivalent-input-disturbance approach. *Internat J Syst. Sci.* 2020;51(1):49-60.
30. Zhang H, Han J, Wang Y, Liu X. Sensor fault estimation of switched fuzzy systems with unknown input. *IEEE Trans. Fuzzy Syst.*. 2017;26(3):1114-1124.
31. Zhao Y, Zhao J. H_{∞} reliable bumpless transfer control for switched systems with state and rate constraints. *IEEE Trans. Syst. Man Cybern. Syst.*. doi: 10.1109/TSMC.2018.2871335.
32. Mallocci I, Hetel L, Daaifouz J, Lung C, Szczepanski P. Bumpless transfer for switched linear systems. *Automatica.* 2012;48(7):1440-1446.
33. Shi J, Zhao J. State bumpless transfer control for a class of switched descriptor systems. *IEEE Trans. Circuits Syst. I, Reg. Papers.* 2021;68(9):3846-3856.
34. Shi Y, Sun X. Bumpless transfer control for switched linear systems and its application to aero-engines. *IEEE Trans. Circuits Syst. I, Reg. Papers.* 2021;68(5):2171-2182.
35. She J, Ohyama Y, Nakano M. A new approach to the estimation and rejection of disturbances in servo systems. *IEEE Trans. Control Syst. Technol.*. 2005;13(3):378-385.
36. Xue W, Bai W, Yang S, Song K, Huang Y, Xie H. ADRC with adaptive extended state observer and its application to air-fuel ratio control in gasoline engines. *IEEE Trans Ind Electron.* 2015;62(9):5847-5857.
37. Xu Y, Sun J, Wang G, Wu Z. Dynamic triggering mechanisms for distributed adaptive synchronization control and its application to circuit systems. *IEEE Trans. Circuits Syst. I, Reg. Papers.* 2021;68(5):2246-2256.
38. Xiang W, Tran D, Johnson T. Nonconservative lifted convex conditions for stability of discrete-time switched systems under minimum dwell-time constraint. *IEEE Trans. Automat. Contr.*. 2016;61(11):3619-3624.
39. Li Z, Zhao J. Almost output regulation of switched affine systems and its application to a circuit model. *IEEE Trans. Circuits Syst. II, Exp. Briefs.* 2021;68(10):3256-3260.
40. Zhao X, Zhao J. L_2 -gain analysis and output feedback control for switched delay systems with actuator saturation. *J FRANKLIN I.* 2015;352(7):2646-2664.

